

# CITY OF TUCKER

## ACKNOWLEDGE RECEIPT OF ADDENDUM #1 FORM

ITB #2024-006

### DOWNTOWN PARKING LOT RESURFACING

**Upon receipt, please print and add to your proposal.**

I hereby acknowledge receipt of the supplement pertaining to the above referenced bid.

COMPANY NAME: \_\_\_\_\_

CONTACT PERSON: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY: \_\_\_\_\_ STATE: \_\_\_\_\_ ZIP: \_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

EMAIL ADDRESS: \_\_\_\_\_

\_\_\_\_\_  
SIGNATURE DATE

ITB #2024-006  
ADDENDUM #1

|   | <b>QUESTION</b>  | <b>ANSWER</b>   |
|---|--|---|
| 1 | Can Line Item #9 be substituted with green paint instead of green thermoplastic?   | No, the contract calls for green thermoplastic.   |
| 2 | Will you allow the use of Liquid Anti-Strip Additive in place of Hydrated Lime per the attached GDOT Bulletin?   | No, hydrated lime will be used in the hot mix.  |
| 3 | Is the contractor removing and replacing the 2 bollards in the parking lot?  | No, the bollards are to remain in place the contractor will need to perform hand work to repave around them.  |
| 4 | Will the city remove the powerline pole wire supports before paving? If not how would you like to proceed with those wires that are anchored into the asphalt?   | No, the pole and guide lines are to remain. The contractor will need to perform handwork to repave this area. |
| 5 | There are around 6 concrete parking bumpers missing on the northern corner of the parking lot. Would the city like to address this or should the contractor just mill and pave the asphalt to the grass there? | No, the contract does not require replacing the curb stops. Milling/Paving will take asphalt to the grass.    |
| 6 | Can you provide patch dimensions for the smaller lot?  | City staff will assist in identifying and parking the areas to be patched prior to the paving operations.     |
| 7 | What is the thickness of the patches in the smaller lot?   | Patches needs to be a minimum of 4 inches in depth.   |