

# CITY OF TUCKER

## ACKNOWLEDGE RECEIPT OF ADDENDUM #1 FORM

ITB 2024-015

LILBURN STONE MOUNTAIN ROAD AND  
DOWNTOWN PARKING LOT RESURFACING  
PROJECT

**Upon receipt, please print and add to your proposal.**

**I hereby acknowledge receipt of the supplement pertaining to the  
above referenced bid.**

COMPANY NAME: \_\_\_\_\_

CONTACT PERSON: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY: \_\_\_\_\_ STATE: \_\_\_\_\_ ZIP: \_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

EMAIL ADDRESS: \_\_\_\_\_

\_\_\_\_\_

**SIGNATURE**

**DATE**

**ITB 2024-015**  
**ADDENDUM #1**

	<b>QUESTION</b>	<b>ANSWER</b>
1	Could you please provide limits(begin and end points) for this project?	From Old Stone Mountain Road to the City Limits south of Tall Pine Court.
2	What are the hours we can work? Any restrictions?	9:00 am to 4:00 pm roadwork hours on Lilburn Stone Mountain Road; 7:00 am to 7:00 pm is permissible for the parking lot area. Coordination may be needed for any City event downtown.
3	Will City provide railroad flagger if needed?	No, flagging would be part of the traffic control line item.
4	What are the limits for Lilburn Stone Mountain Road?	From Old Stone Mountain Road to the City Limits south of Tall Pine Court.
5	Will we be paving turn lanes on Lilburn Stone Mountain Rd as well or will it only be the mainline?	There are no turn lanes within the limits of the project.
6	Will shoulder work be required for any portions of Lilburn Stone Mountain Rd? If so, can an item be added to the bid schedule?	No shoulder work is required.
7	Can tripod signs be used in place of post-mounted warning signs?	Yes, tripod signage is acceptable.
8	Will striping tape be acceptable for temp striping?	Yes, tape may be used temporarily while the asphalt cures prior to the permanent thermoplastic markings.
9	Do you have any plans available for the traffic loop location?	No. The 6"x40' loop and 6"x 6" setback loop are located at the intersection of Old Stone Mountain Road and are to be replaced in kind.