

# CITY OF TUCKER

## ACKNOWLEDGE RECEIPT OF ADDENDUM #3

ITB 2025-001

### STORMWATER SYSTEM REPAIR PROJECTS

**Please print this page and include it in your submittal.**

I hereby acknowledge receipt of the supplement pertaining to the above referenced bid.

COMPANY NAME: \_\_\_\_\_

CONTACT PERSON: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY: \_\_\_\_\_ STATE: \_\_\_\_\_ ZIP: \_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

EMAIL ADDRESS: \_\_\_\_\_

\_\_\_\_\_  
SIGNATURE

\_\_\_\_\_  
DATE

ITB 2025-001  
ADDENDUM #3

This addendum provides clarification for Question #3 as published in Addendum #1.

	<b>QUESTION</b>	<b>ANSWER</b>
3	The bid tab appears to reference Felt CIPP , will the City of Tucker accept UV CIPP with this bid? If so, what are the thickness requirements?	The thickness requirements for each location and pipe size are called out in the unit price cost proposal form. Yes, we will accept UV Liners. The thickness should be the equivalent thickness as compared to Felt CIPP.