

CITY OF TUCKER

ACKNOWLEDGE RECEIPT OF ADDENDUM #1

Publish Date: November 20,2025

ITB #2025-018

STORMWATER SYSTEM CULVERT REPAIR PROJECTS

Please complete this page and include this page only in bid submittal.

**I hereby acknowledge receipt of the supplement pertaining to the
above referenced bid.**

COMPANY NAME: _____

CONTACT PERSON: _____

ADDRESS: _____

CITY: _____ **STATE:** _____ **ZIP:** _____

PHONE: _____ **FAX:** _____

EMAIL ADDRESS: _____

SIGNATURE

DATE

ITB #2025-018
STORMWATER SYSTEM CULVERT REPAIR PROJECTS
ADDENDUM #1

	QUESTION	ANSWER
1	For Location A, There is a Conc Spillway to be cast in place. However, the plans show a concrete flume. Can you please provide clarity on what you would like for this location and what is to be included in the unit price?	The terns “Spillway” and “Flume” are used to describe the same drainage feature. The intention is to construct the “GDOT Standard Detail 9013, Type 4”. This detail can be found in the plan set on Drawing C5.0 in the lower left.