

PCITY OF TUCKER

ACKNOWLEDGE RECEIPT OF ADDENDUM #2

Publish Date: May 26, 2026

ITB #2026-015

STORMWATER SYSTEM REPAIR PROJECTS

Please complete this page and include this page only in bid submittal.

I hereby acknowledge receipt of the supplement pertaining to the above referenced bid.

COMPANY NAME: _____

CONTACT PERSON: _____

ADDRESS: _____

CITY: _____ STATE: _____ ZIP: _____

PHONE: _____ FAX: _____

EMAIL ADDRESS: _____

SIGNATURE

DATE

ITB #2026-015
ADDENDUM #2

	QUESTION	ANSWER
1	Within the ITB document, under <i>Purpose, Intent and Project Description</i> , to download the complete scope and information for this task order 49, we must request information through this email. Could you please share the additional files with me?	There have been no more documents created to be shared. The complete solicitation is: ITB 2026-015 Bid Manual ITB 2026-015 Addendum 1 This Addendum: ITB 2026-015 Addendum 2
2	Is there a list of approved hydrants that the contractor is allowed to use for the cleaning and rehab of this project?	Hydrants within the public right of way may be used. Contractor must have their own portable meter account with Dekalb County.
3	Under the special conditions, it states if contractors use hydrants than the water must be metered. Will the Owner provide the water meters, and will the Owner provide the water at no cost to the contractor?	No. Water meters shall be provided by the contractor and paid for via the line item for cleaning.
4	Under Special Conditions, it state that removed material must be contained in leak-proof containers and hauled to an approved disposal facility. Please confirm the type of waste classification (e.g., non-hazardous, special waste, municipal solid waste) for the sediment and water mixture.	There may be a combination of waste. It's unknown what to expect. However, waste shall be disposed of accordingly. That is, if hazardous waste is found/identified, it shall be disposed of at the proper disposal location and handling.
5	Will the contractor be provided with a dumpsite for sewer debris at no cost?	No. That shall be included in the cost of cleaning.
6	Will the Owner provide an overnight parking site for equipment at no cost to the contractor?	No.
7	What is the budget for each location or overall?	The city does not disclose project budgets during the bidding process.
8	If funding is insufficient to award both locations, please confirm whether the Owner intends to remove locations from the award.	If unable to fund – this bid will be rejected and edits to the scope will be made by City staff and readvertised.

ITB #2026-015
ADDENDUM #2

9	If locations may be removed, please provide the priority order or ranking of locations so bidders can understand how the Owner intends to sequence or select work based on available funding.	Unable to address at this time.
10	What is the required warranty for the scope of work?	1 – year on workmanship/labor. Materials are dependent on manufacturer.
11	Can the Owner/Engineer please confirm what permits will be anticipated for the contractor to obtain, and what are the cost of those anticipated permits?	All of the work is to be completed within 25ft of the pipes. As such, this is classified as maintenance and will not require any permits.